



SUPPLEMENTAL/BID BULLETIN

BID BULLETIN NO. 01 30 March 2020

Name of Project: **Supply, Delivery, Installation, Test, and Commissioning of One (1) Unit Diesel Generator Set System Including its Ancillaries and/or Accessories with Rehabilitation of Generator and Switchgear Rooms of TESDA Central Office Main Building – Rebidding**

Pursuant to Section 22.5 of the Revised Implementing Rules and Regulations of Republic Act No. 9184, this Bid Bulletin No. 1 is being issued to further clarify the provisions in the Bidding Documents with reference to the queries/concerns raised by the bidder/s.

A. CLARIFICATION IN THE BIDDING DOCUMENTS:

1. On the Submission of Certificate of Performance Evaluation (Clause 20.1 of the Bid Data Sheet)

QUERY/CONCERN	Innovalite Inc. requested to use the previous Certificate of Performance Evaluation issued by Surigao Del Sur State University since the signatory for said document is under a work-from-home arrangement.
RESPONSE	An electronic signature on the document would suffice. The attached form in the Bidding Documents of TESDA for the abovementioned procurement will be used.

2. On the Requirement for Control Panel (Annex C under Section VII [Technical Specifications] of the Bidding Documents)

QUERY/CONCERN	Innovalite Inc. requested if the Digital Control Panel is acceptable since all features is in a compact digital panel.
RESPONSE	The Digital Control Panel will be considered if these conditions are met: <ul style="list-style-type: none">• All the parameters/devices required under Annex C: Pre-Commissioning Inspection: Control Panel are present;

	<ul style="list-style-type: none"> • The offered Digital Control Panel can withstand a high degree of environmental tolerance like high humidity and large concentration of dust and debris; and • The Digital Control Panel defective parts are replaceable/repairable without replacing the entire digital control panel.
--	---

B. CLARIFICATION IN THE INVITATION TO BID:


1. On the schedule of the bid submission (Paragraph 7)

ORIGINAL	AMENDED
Bids must be duly received by the BAC Secretariat through manual submission at the office address indicated below on or before 8 April 2021 at 2:00 p.m. Online submission is not yet available. Late bids shall not be accepted.	Bids must be duly received by the BAC Secretariat through manual submission at the office address indicated below on or before 15 April 2021 at 2:00 p.m. Online submission is not yet available. Late bids shall not be accepted.

2. On the schedule of the opening of bids (Paragraph 9)

ORIGINAL	AMENDED
Bid opening shall be on 8 April 2021 at 2:15 p.m. , at the Gabriela Silang Room, TESDA Women's Center, Gate 1, TESDA Complex, Building 2, East Service Road, South Luzon Expressway (SLEX), Fort Bonifacio, Taguig City 1630. Bids will be opened in the presence of the bidders' representatives who choose to attend the activity.	Bid opening shall be on 15 April 2021 at 2:15 p.m. , at the Gabriela Silang Room, TESDA Women's Center, Gate 1, TESDA Complex, Building 2, East Service Road, South Luzon Expressway (SLEX), Fort Bonifacio, Taguig City 1630. Bids will be opened in the presence of the bidders' representatives who choose to attend the activity.

For the information and guidance of all concerned.


DDG LINA C. SARMIENTO
 Chairperson 
 Bids and Awards Committee 